

SMARTCOOL™

ECO³™ Single Channel Savings Analysis by Codelogistics, Inc.

Client: Restaurant in New Port Richey, FL (Kitchen Unit #2)

Electric Rate: Rate: \$0.11 /KWH

Total Bill: \$4,806.89

Total KWH: 43760

Equipment:

Description: Heat Pump

Phase (1 or 3): 3

RLA: 17.3 KWH: 7.18 per hour

FLA: 0.8 Cost: \$0.79 per hour

Voltage: 230

Unit Readout:

Run: 62

Save: 52

Bypass: 100

Savings Analysis:

Spent: \$127.81

Saved: \$41.02 24%

Trial Days: 10

Monthly Savings: \$127.18

ROI: 0.8 yrs

Without Smartcool:

Would have Spent: \$168.83